



**WASHTENAW COUNTY
FINANCE DEPARTMENT**

Purchasing Division

P.O. Box 8645, 220 N. Main, Ann Arbor, MI 48107-8645
Phone (734) 222-6760, Fax (734) 222-6764
www.purchasing.ewashtenaw.org

June 18, 2007

RFP # 6346 Amendment # 1

Subject Asphalt Patching and Seal Coating Services Pre-bid Meeting Notes

Location Meri Lou Murray Recreation Building

Washtenaw County Parks & Recreation wishes to amend our bid document for Asphalt Patching & Seal Coating Services as discussed at the pre-bid meeting 10:00 AM on June 15, 2007 at the Meri Lou Murray building. The bid needed to list the asphalt material specification required for the patching and seal coat instruction for work at the Meri Lou Murray building and the Pierce Lake Golf Course lots & drive ways.

- Do not seal coat the newly installed asphalt leave it exposed.
- For the cut out & replace method apply two & one half inches (2 1/2") minimum of "Base Mix" asphalt for the base, & additional one & one-half inches (1 1/2") Top Mix 1100T-20AA layer, totaling four inches in a level and professional manner.
- For the milling method grind down to solid asphalt & replace with two courses of same asphalt specification to a level surface.

Attendees Sealcoating Plus Inc
 S & J Asphalt Paving Company
 Action Asphalt & Concrete, Inc
 Belden Paving Co. Inc
 T & M Asphalt Paving, Inc
 Alan's Asphalt Maintenance, Inc

Any questions, contact Robert Devault at (734) 222-6760 devaultb@ewashtenaw.org or Tom Leabu at 734-971-6337 x 316 or leabut@ewashtenaw.org

Robert G. Devault, C.P.M.
Purchasing Manager

cc: Bid # 6346