

March 18, 2008

Pierce Lake Golf Course and Park  
New Restrooms  
Chelsea, MI  
Washtenaw County Parks and Recreation

**ADDENDUM NO. 2 to the Contract Documents / dated February 22, 2008 / RFP #6389**

**General Information / Pre-Bid Meeting Information**

---

- CHANGE** The website to obtain prevailing wage information was incorrectly listed in Addendum #1. It should have read: [http://www.dleg.state.mi.us/bwuc/bsr/wh/rates\\_2008/qtr1/Washtenaw.pdf](http://www.dleg.state.mi.us/bwuc/bsr/wh/rates_2008/qtr1/Washtenaw.pdf).
- CLARIFY** The Contractor is responsible for all utilities to 5 feet outside the new building. Contractor is also responsible for connections to new Owner provided well / pressure tank and sanitary grinder pump. Since the exact location of new well and grinder pump are not known at this time, any distance beyond 5 feet will be an add to the contract.
- CLARIFY** It is acceptable for the Contractor to provide an underground splice at the existing electrical to feed the new building. Since exact location of the building is not known, the bid shall include underground splice and moving existing feed. However, the distance between the existing line and 5 feet outside the new building will be an add to the contract.

**ATTACHMENTS: None**

**END OF ADDENDUM NO. 2**